

इंटरनेट

मानक

Disclosure to Promote the Right To Information

Whereas the Parliament of India has set out to provide a practical regime of right to information for citizens to secure access to information under the control of public authorities, in order to promote transparency and accountability in the working of every public authority, and whereas the attached publication of the Bureau of Indian Standards is of particular interest to the public, particularly disadvantaged communities and those engaged in the pursuit of education and knowledge, the attached public safety standard is made available to promote the timely dissemination of this information in an accurate manner to the public.

“जानने का अधिकार, जीने का अधिकार”

Mazdoor Kisan Shakti Sangathan

“The Right to Information, The Right to Live”

“पुराने को छोड़ नये के तरफ”

Jawaharlal Nehru

“Step Out From the Old to the New”

IS 14746 (1999, Reaffirmed 2009): Respiratory Protective Devices--Half Masks And Quarter Masks--Specification. ICS 13.340.30



“ज्ञान से एक नये भारत का निर्माण”

Satyanarayan Gangaram Pitroda

“Invent a New India Using Knowledge”



“ज्ञान एक ऐसा खजाना है जो कभी चुराया नहीं जा सकता है”

Bhartrhari—Nitiśatakam

“Knowledge is such a treasure which cannot be stolen”

C 179

IS 14746 : 1999
REAFFIRMED

-- FEB 2009

भारतीय मानक

श्वसन रक्षी युक्तियाँ — आधे चेहरे को ढकने के मुखौटे
तथा केवल नाक और मुँह को ढकने के मुखौटे — विशिष्ट

Indian Standard

RESPIRATORY PROTECTIVE DEVICES — HALF
MASKS AND QUARTER MASKS — SPECIFICATION

ICS 13.340.30

© BIS 1999

BUREAU OF INDIAN STANDARDS
MANAK BHAVAN, 9 BAHADUR SHAH ZAFAR MARG
NEW DELHI 110002

December 1999

Price Group 8

FOREWORD

This Indian Standard was adopted by the Bureau of Indian Standards, after the draft finalized by the Industrial Safety Sectional Committee had been approved by the Chemical Division Council.

Half masks and quarter masks are widely used in the environment where there is contamination of toxic or hazardous gases in the air. Depending on concentration and nature of the contamination, the half masks or quarter masks are used. While formulating this standard considerable assistance has been taken from EN 140:1989 'Specification for half masks and quarter masks for respiratory protective devices', published by European Committee for Standardization, Brussels. This standard is generally in line with EN 140:1989.

The composition of the technical committee responsible for formulating this standard is given at Annex C.

For the purpose of deciding whether a particular requirement of this standard is complied with, the final value, observed or calculated, expressing the result of a test or analysis, shall be rounded off in accordance with IS 2 : 1960 'Rules for rounding off numerical values (*revised*)'. The number of significant places retained in the rounded off value should be the same as that of the specified value in this standard.

*Indian Standard***RESPIRATORY PROTECTIVE DEVICES — HALF MASKS AND QUARTER MASKS — SPECIFICATION****1 SCOPE**

This standard prescribes requirements for half masks and quarter masks for use as part of respiratory protective devices, except escape apparatus and diving apparatus.

Laboratory and practical performance tests are included for the assessment of compliance with the requirements.

2 REFERENCES

The Indian Standards listed below contain provisions, which through reference in this text constitute provisions of this Indian Standard. At the time of publication, the editions indicated were valid. All standards are subject to revisions, and parties to agreements based on this Indian Standard are encouraged to investigate the possibility of applying the most recent editions of the Indian Standards indicated below:

<i>IS No.</i>	<i>Title</i>
4905 : 1968	Methods of random sampling
8347 : 1977	Glossary of terms relating to respiratory protective devices
14138 (Part 1) : 1994	Respiratory protective devices; Threads for facepieces : Part 1 Standard thread connection—Specification
14166 : 1994	Respiratory protective devices — Full face masks — Specification

3 TERMINOLOGY

For the purpose of this standard following definitions shall apply.

3.1 Half Mask

A half mask is a facepiece, which covers the nose, mouth and chin. They are intended to provide adequate sealing on the face of the wearer of a respiratory protective device against the ambient atmosphere, when the skin is dry or moist and when the head is moved.

3.2 Quarter Mask

A quarter mask is facepiece which covers the nose, mouth and chin. They are intended to provide adequate sealing on the face of the wearer of a respiratory protective device against the ambient atmosphere, when the skin is dry or moist and when the head is moved.

3.3 In addition to the above, for the purpose of this standard, the definitions given in IS 8347 shall also apply.

4 REQUIREMENT**4.1 Materials**

Exposed parts of half masks and quarter masks, that is, those which may be subjected to impact during use of the apparatus shall not be made of aluminium, magnesium and titanium or alloys containing such proportions of these metals as will, on impact, give rise to frictional sparks capable of igniting flammable gas mixtures.

4.2 Design

The masks shall be so designed that air enters the facepiece and passes directly to the nose and mouth area of the facepiece. The exhaled air flows directly to the ambient atmosphere, via the exhalation valve(s) or by other appropriate means.

4.3 Cleaning and Disinfecting

The materials used shall withstand the cleaning and disinfecting agents recommended by the manufacturer.

4.4 Replaceable Components

Unless integral with the half mask or the quarter mask the following components (when fitted) shall be replaceable:

Head harness, connector(s), inhalation and exhalation valves.

Such components shall be visually inspected according to A-1.

4.5 Practical Performance Test

The complete apparatus shall undergo practical performance tests under realistic conditions. These general tests serve the purpose of checking the

equipment for imperfections that cannot be determined by the tests described elsewhere in this standard. In addition to the tests described in this standard details of practical performance tests for breathing apparatus are given in the relevant Indian Standard. Where a half mask or quarter mask is to be used for filtering devices, testing shall be in accordance with A-2.

When practical performance tests show the apparatus has imperfections related to wearer's acceptance, full details of those parts of practical performance tests, which revealed these imperfections, shall be provided. This will enable during subsequent testing of the masks to repeat the tests and assess the results thereof.

4.6 Resistance of Temperature

After storing the masks at specified temperature in accordance with A-3 and then returning to room temperature, the facepiece shall not show appreciable deformation.

After the resistance to temperature test the facepiece shall be tested for inward leakage and shall meet the requirements of 4.7.

4.7 Inward Leakage of Facepiece

The facepiece shall fit against the contours of the face so that, when tested in accordance with A-4, the inward leakage of the test contaminant shall not exceed a time average value of 5 percent of the inhaled air for any of the required ten test subjects in any of the test exercises.

The mean of all exercises for any one person shall not exceed 2 percent. The measured inward leakage includes the exhalation valve leakage.

NOTE — A recommended procedure for measuring the contribution from leakage through an exhalation valve is given in Annex B. It should not exceed 0.05 percent.

4.8 Compatibility with Skin

Materials that may come into contact with the wearer's skin shall not be known to have potential to cause irritation or any adverse effect to health.

4.9 Flammability

The material used shall not present a danger for the wearer and shall not be of highly flammable nature. When tested in accordance with A-5 the facepiece shall not continue to burn after removal from the flame. It is not required that the facepiece still has to be usable after the test.

4.10 Carbon Dioxide Content of the Inhalation Air

When tested in accordance with A-6 the carbon dioxide content of the inhalation air (dead space) shall not

exceed an average of 1.0 percent (by volume).

4.11 Head Harness

4.11.1 The head harness shall be so designed that the facepiece can be donned and removed easily, when tested according to A-2.

4.11.2 The head harness shall be adjustable or self-adjusting and shall hold the facepiece firmly and comfortably in position, when tested according to A-2.

4.11.3 Each strap of the head harness shall withstand a pull of 50 N applied for 10 seconds in the direction of pulling when the facepiece is donned.

4.12 Facepiece Connector

When tested according to A-1, the masks shall conform to the requirements given in 4.12.1, 4.12.2 and 4.12.3.

4.12.1 The connections between the facepiece and the apparatus may be achieved by a permanent or special (for example insert) type of connection or by a standard thread connection. If a standard thread connection is used for example for a single filter mask then the relevant requirements of IS 14138 (Part 1) shall be satisfied.

4.12.2 A facepiece shall not have more than one standard thread connection. If any other screw thread is used it shall not be possible to connect it to the standard thread. If a screw thread is used for a twin filter facepiece it shall not be possible to connect it to the standard thread. Half masks and quarter masks shall not be equipped with a centre thread connector.

4.12.3 The connection between the faceblank and the connector shall be sufficiently robust to withstand axially a tensile force of 50 N when tested in accordance with A-7.

Correct and reliable connection between facepiece and other parts of the equipment shall be ensured.

4.13 Field of Vision

The field of vision shall be acceptable when determined so during the practical performance tests. Comparative testing of the field of vision is carried out in accordance with the method described in A-8.

4.14 Inhalation and Exhalation Valves

Valves assemblies shall be such that they can be readily maintained and correctly replaced. It shall not be possible to fit an exhalation valve assembly into the inspiratory circuit or an inhalation valve assembly into the exhalation circuit, when tested in accordance with A-1.

4.14.1 Inhalation Valve(s)

4.14.1.1 The facepiece should preferably be provided

with one or more inhalation valve(s). If a standard thread connection is used, an inhalation valve shall be incorporated in the facepiece. If the facepiece has to be used with filters it shall be provided with an integral inhalation valve, if there is no valve in the filter.

4.14.1.2 Inhalation valve(s) shall function correctly in all orientations.

4.14.2 *Exhalation valve(s)*

4.14.2.1 Exhalation valve(s) shall function correctly in all orientations.

4.14.2.2 The facepiece shall have at least one exhalation valve or appropriate means to allow the escape of exhaled air and, where applicable, any excess air delivered by the air supply.

4.14.2.3 The exhalation valve(s) shall be protected against dirt and mechanical damage and shall be shrouded or shall include any other device that may be necessary to comply with 4.7.

4.14.2.4 The exhalation valve(s) shall continue to operate correctly after a continuous exhalation flow of 300 l/min over a period of 30 seconds. Test specimen shall be in the state as received.

4.14.3 When the exhalation valve housing is attached to the faceblank, it shall withstand axially a tensile force of 50 N applied for 10 seconds. Test specimens shall be in the state as received.

4.15 Breathing Resistance

When tested in accordance with A-9, the breathing resistance of the facepiece shall not exceed 2.0 mbar¹⁾ for inhalation and 3.0 mbar for exhalation when tested with a breathing machine (25 × 2 l/min) or a continuous flow of 160 l/min.

The inhalation resistance shall not exceed 0.5 mbar at 30 l/min continuous flow and 1.3 mbar at 95 l/min continuous flow.

4.16 De-mountable Parts

All de-mountable connections shall be readily connected and secured, where possible by hand. Any means of sealing used shall be retained in position when the connection is disconnected during normal maintenance.

5 MARKING

5.1 All units of the same model shall be provided with a type identifying marking. Sub-assemblies and components with considerable bearing on safety shall be marked so that they can be identified. The manufacturer shall be identified by name, trade-mark or other means of identification.

5.2 Where the reliable performance of components may be affected by ageing, means of identifying the date (at least the year) of manufacture shall be marked. For parts, which cannot be marked, the relevant information shall be included in the instructions for use.

5.3 The marking shall be as clearly visible and as durable as possible.

5.4 BIS Certification Marking

The half masks and quarter masks may also be marked with the Standard Mark.

5.4.1 The use of the Standard Mark is governed by the provisions of *Bureau of Indian Standards Act, 1986* and Rules and Regulations made thereunder. The details of conditions under which the licence for use of Standard Mark may be granted to manufacturers or producers may be obtained from the Bureau of Indian Standards.

6 INSTRUCTIONS FOR USE

6.1 On delivery instructions for use shall accompany every facepiece.

6.2 Instructions for use shall be in one or more languages acceptable to the country of application.

6.3 The instructions for use for the equipment shall contain all information necessary for trained and qualified persons on:

- application/limitation;
- checks prior to use;
- donning, fitting;
- use;
- maintenance (preferably separately printed instructions); and
- storage.

6.4 The instructions shall be unambiguous. If helpful, illustrations, part number, marking, etc, shall be added.

6.5 Warning shall be given against problems likely to be encountered, for example:

- fit of facepiece (check prior to use);
- it is unlikely that the requirements for leakage will be achieved if facial hair passes under the face seal;
- hazards of oxygen and oxygen-enriched air;
- air quality; and
- use of equipment in explosive atmosphere.

¹⁾ 1 bar = 105 N/m² = 100 kPa.

7 SAMPLING AND CRITERIA FOR CONFORMITY

7.1 Lot

In a single consignment, all the half masks and quarter masks assembled under uniform conditions of manufacture on the same day, shall constitute a lot.

7.1.1 Each lot shall be tested separately for ascertaining the conformity of the lot to the requirements of the specification. The number of face masks to be selected from the lot shall depend upon the size of the lot and shall be in accordance with Table 1.

7.1.2 The masks shall be selected at random from the lot. For this purpose, reference may be made to IS 4905.

Table 1 Number of Samples to be Tested from a Lot
(Clause 7.1.1)

Sl No.	No. of Face Masks in the Lot	No. of Face Masks to be Selected in a Sample
(1)	(2)	(3)
i)	Up to 50	8
ii)	51 to 150	13
iii)	151 and above	20

7.2 Number of Tests

7.2.1 Each of the face masks selected from the lot according to col 2 of Table 1 shall be examined for visual inspection (4.4, 4.12 and 4.14) and field of vision (4.13).

7.2.1.1 The lot shall be considered to have satisfied the above requirements if none of the masks in the sample fails. Otherwise, the lot shall be rejected.

7.2.2 The sample having been found satisfactory as per 6.2.1 shall be further tested for the requirements of carbone dioxide content (4.10), breathing resistance (4.15), practical performance test (4.5), and cleaning and disinfection (4.3) in this sequence.

7.2.2.1 The lot shall be considered to have satisfied the above requirements if there is no failure in the sample. Otherwise, the lot shall be rejected.

7.2.3 Approximately half the number of masks, out of the sample already been found satisfactory as per 6.2.2, shall be conditioned as per 4.6 and shall be tested for inward leakage of facepiece (4.7), flammability (4.9), and inhalation and exhalation valve (4.14).

7.2.3.1 The other half of the sample shall be tested for the requirements of facepiece (4.7), flammability (4.9), head harness tests (4.11.3 and 4.11.4) facepiece connector (4.12), exhalation valves (4.14.2),

Table 2 Summary of Test
(Clause 7.3)

Sl No.	No. of Samples	Test Criteria	Pre-conditioning (Yes/No)	Clause
(1)	(2)	(3)	(4)	(5)
i)	All	Visual inspection	No	4.4/4.12 4.14/A-1
ii)	5	Cleaning and disinfection For total inward leakage tests	As recommended By manufacturer	4.3/ A-1/A-4
iii)	3	Head harness tests pull test	No	4.11.3
iv)	3	Facepiece connector pull test	No	4.12.2/A-7
v)	3	Exhalation valve housing pull test	No	4.14.3
vi)	5	Facepieces Exhalation valves Performance tests Continuous flow optional leakage test	No 2 conditioned 3 as received then use for leakage test	4.14.2/ 4.14.2.4/ Annex B
vii)	3	Flammability	No	4.9/A-5
viii)	1	Carbon dioxide content	No	4.10/A-6
ix)	3	Breathing resistance	No	4.15/A-9
x)	5	Inward leakage	2 conditioned ¹⁾ 3 as received	4.7/A-4
xi)	2	Practical performance test	No	4.5/4.11.1 4.11.2/4.13/ A-2

NOTE — Most samples are used for more than one test.

¹⁾ Conditioning/resistance to temperature (see 4.6 and A-3).

performance tests (4.14.2.4) and exhalation valves housing (4.14.3).

7.2.3.2 The lot shall be considered as conforming to the requirements of this specification if all the face

masks pass the requirements specified in 7.2.3. Otherwise the lot shall be rejected.

7.3 A summary of tests applicable for half masks and quarter masks is given in Table 2.

ANNEX A

(Clauses 4.4, 4.5, 4.6, 4.7, 4.9, 4.10, 4.11.1, 4.12, 4.12.3, 4.13, 4.14 and 4.15)

METHODS OF TESTS FOR HALF MASKS AND QUARTER MASKS

A-1 VISUAL INSPECTION

The visual inspection is carried out, where appropriate, by the manufacturer prior to laboratory or practical performance tests.

A-2 PRACTICAL PERFORMANCE TEST

All tests shall be carried out by two test subjects at ambient temperature and the test temperature and humidity shall be recorded. For the test, persons shall be selected who are familiar with using such or similar equipment.

During the tests, facepiece shall be subjectively assessed by the wearer and after the test, comments on the following shall be recorded:

- a) Harness comfort;
- b) Security of fastenings and couplings;
- c) Accessibility of controls (if fitted);
- d) Clarity of vision on the visor of the facepiece (if fitted);
- e) Any other comments reported by the wearer on request; and
- f) Field of vision (to be determined with the component to be used directly on the facepiece).

A-2.1 Walking Test

The subjects wearing normal working clothes and wearing the facepiece fitted with a filter simulator (Fig. 3) shall walk at a regular rate of 6 km/h on a level course. The test shall be continuous, without removal of the facepiece, for a period of 10 min.

A-2.2 Work Simulation Test

- a) *Facepieces with standard thread connection*
The facepiece shall be fitted with a filter simulator (Fig. 3).
- b) *Facepieces with special connections*
The facepiece shall be fitted with the filters supplied by the manufacturer.

c) Test procedure

Each combination shall be tested under conditions which can be expected during normal use. During this test the following activities shall be carried out in simulation of the practical use of the apparatus. The test shall be completed within a total working time of 20 min.

The sequence of activities shall be as agreed to between the purchaser and the supplier. The individual activities shall be arranged so that sufficient time is left for the comments prescribed.

- a) Walking on the level with headroom of 1.1 to 1.5 m for 5 min.
- b) Crawling on the level with headroom of less than 0.75 m for 5 min.
- c) Filling a small basket (see Fig. 1, approximately volume = 8 l) with 'rubber chippings' or other suitable material from a hopper which stands 1.5 m high and has an opening at the bottom to allow the contents to be shovelled out and rubber chippings shall be returned.

The subject shall stoop or kneel as he wishes and fill the basket with rubber chippings. He shall then lift the basket and empty the contents back into the hopper. This shall be repeated 15 to 20 times in 10 min.

A-3 RESISTANCE TO TEMPERATURE

Two facepieces shall be treated in the state as received. The facepiece shall be exposed during successive tests:

- a) for 24 hours to a dry atmosphere of $70 \pm 3^\circ\text{C}$; and
- b) for 24 hours to a temperature of $-30 \pm 3^\circ\text{C}$.

A-4 INWARD LEAKAGE OF FACEPIECE

The laboratory tests shall indicate that the facepiece can be used by the wearer to protect with high probability against the potential hazard to be expected. The sodium chloride and sulphur hexafluoride methods are equally acceptable options. The inward leakage shall be tested with 5 facepieces, two of them already preconditioned in accordance with A-3.

A-4.1 General Test Procedure

A-4.1.1 Inward Leakage

Prior to the test there shall be an examination that, the facepiece is in good working condition and that it can be used without hazard. For the test, persons shall be selected who are familiar with using such or similar equipment.

A panel of ten clean-shaven persons (with beard or sideburns shall be selected covering the spectrum of facial characteristics of typical users (excluding significant abnormalities). It is to be expected that exceptionally some persons cannot be satisfactorily fitted with a facepiece. Such exceptional subjects shall not be used for testing facepieces. In the test report the faces of the ten test persons shall be described (for information only) by the four following facial dimensions (in mm) illustrated in Fig. 2.

If more than one size of facepiece is manufactured the

test subjects shall be supplied with the appropriate size.

A-4.1.2 Apparatus

A-4.1.2.1 Test atmosphere

The test atmosphere shall preferably enter the top of the hood/chamber through a flow distributor and be directed downwards over the head of the test subject at a minimum velocity of 0.12 m/s. The concentration of the test agent inside the effective working volume shall be checked to be homogeneous. The velocity should be measured close to the subject's head.

The design of the hood/chamber shall be such that the test subject wearing the facepiece under test can be supplied with breathable air (free of test atmosphere).

A-4.1.2.2 Treadmill

A level treadmill is required capable of working at 6 km/h.




FIG.1 BASKET AND HOPPER RUBBER CHIPPINGS





FIG. 2 FACIAL DIMENSIONS



* See EN 148-1 : 1987

All dimensions in millimetres.

FIG. 3 FILTER SIMULATOR FOR STANDARD THREAD FILTERS/HALF MASKS OR QUARTER MASKS

A-4.1.2.3 Filter simulator

If the facepiece is to be used with a filter having a standard thread, a device is required to simulate the maximum weight and resistance of filters permitted for that type of facepiece (Fig. 3). This simulator shall be connected to a clean air supply by an ultralight-weight flexible hose. If the facepiece uses a special connection, the clean air supply shall be attached to the filter or equipment normally used with the facepiece. It is important that the attachment of the clean air hose to the facepiece does not affect the fit of the facepiece and if necessary the hose shall be supported.

The filter simulator shall not weigh more than 300 g and the weight shall be equally distributed along the length. Pressure drop shall be 1 mbar at 95 l/min.

A-4.1.3 Procedure

The test subjects shall be asked to read the manufacturers's fitting instruction, and if necessary shown by the test supervisor how to fit the facepiece correctly, in accordance with the fitting instructions.

The test subjects shall be informed that if they wish to adjust the facepiece during the test they may do so. However if this is done, the relevant section of the test shall be repeated having allowed the system to settle. The test subjects shall have no indication of the results as the test proceeds.

After fitting the facepiece each test subject shall be asked "Does the mask fit?" If the answer is "Yes", continue the test. If the answer is "NO", take the test subject off the panel, report the fact and replace the person by another test subject.

The test sequence shall be as follows:

- a) Ensure the test atmosphere is OFF.

- b) Place that the test subject in the hood/chamber. Connect up the facepiece sampling probe. Have the test subject walk at 6 km/h for 2 min. Measure the test agent concentration inside the facepiece to establish the background level.
- c) Obtain a stable reading.
- d) Turn the test atmosphere ON.
- e) The subject shall continue to walk for a further 2 min or until the test atmosphere has stabilized.
- f) While still walking the subject shall perform the following exercises:
 - i) Walking for 2 min without head movement or taking.
 - ii) Turing head from side to side (approximately 15 times), as if inspecting the wall of a tunnel for 2 min.
 - iii) Moving the head up and down (approximately 15 times), as if inspecting the roof and floor for 2 min.
 - iv) Reciting the alphabet or an agreed text out load as it communicating with a colleague for 2 min.
 - v) Walking for 2 min without head movement or talking.
 - vi) Turn off the test atmosphere and when the test agent has cleared from the chamber remove the subject.

A-4.1.4 Results

Record the following as test results:

- a) chamber concentration; and
- b) the leakage over each exercise period.

After each test the facepiece shall be cleaned, disinfected and dried before being used for its second inward leakage test an another test subject.

A-4.2 Sulphur Hexafluoride (SF₆) Method

A-4.2.1 Principle

The subject wearing the apparatus under test shall walk on a treadmill over which is a hood/chamber. Through this hood/chamber flows a constant concentration of SF₆.

The air inside the facepiece is sampled and analyzed. The sample is extracted by punching a hole in the face blank and inserting a probe through which the sample is drawn.

A-4.2.2 Apparatus (Fig. 4)

A-4.2.2.1 Test agent

This method employs SF₆ as a test gas. The subject wearing the facepiece under test stands with his head surrounded by the SF₆ test atmosphere. Accurate

$$P \text{ (percent)} = \frac{C_2}{C_1} \times 100$$

where

C_1 challenge concentration, and

C_2 measured mean concentration.

Measurement of C_2 is preferably made using an integrating recorder.

A-4.3 Sodium Chloride (NaCl) Method

A-4.3.1 Principle

The subject wearing the facepiece under test walks on a treadmill over which is hood/chamber. Through this hood/chamber flows a constant concentration of NaCl aerosol. The air inside the facepiece is sampled and analyzed during the inhalation phase of the respiratory cycle to determine the NaCl content. The sample is extracted by punching a hole in the faceblank and inserting a probe through which the sample is drawn. The pressure variation inside the facepiece is used to actuate a change-over valve so that inhaled air only is sampled. A second probe is inserted for this purpose.

A-4.3.2 Apparatus

A-4.3.2.1 Aerosol generator

The NaCl aerosol shall be generated from a 2 percent solution of reagent grade NaCl in distilled water. A single large Collision atomizer of the type described shall be used (Fig. 5). This requires an air flow rate of 100 l/min at a pressure of 7 bar. The atomizer and its housing shall be fitted into a duct through which a constant flow of air is maintained. It may be necessary to heat or dehumidify the air in order to obtain complete drying of the aerosol particles.

A-4.3.2.2 Test agent

The mean NaCl concentration within the hood/chamber shall be (8 ± 4) mg/m³ and the variation throughout the effective working volume shall be not more than 10 percent. The particle size distribution shall be 0.02 µm to 2 µm equivalent aerodynamic diameter with a mass median diameter of 0.6 µm.

A-4.3.2.3 Flame photometer

A flame photometer shall be used measure the concentration of NaCl inside the facepiece. Essential performance characteristics for a suitable instrument are :

- It should be a flame photometer specifically designed for the direct analysis of NaCl aerosol.
- It should be capable of measuring concentrations of NaCl aerosol between 15 mg/m³ and 5 mg/m³.

- The total aerosol sample required by the photometer should not be greater than 15 l/min.
- The response time of the photometer, excluding the sampling system, should not be greater than 500 ms.
- It is necessary to reduce the response to other elements, in particular carbon, the concentration of which will vary during the breathing cycle. This will be achieved by ensuring that the band pass width of the interference filter is no greater than 3 nm and that all necessary side-band filters are included.

A-4.3.2.4 Sample selector

A system is required which will switch the sample to the photometer only during the inhalation phase of the respiratory cycle. During the exhalation phase clean air shall be fed to the photometer. The essential elements of such a system are:

- an electrically operated valve with a response time of the order of 100 ms. The valve should have the minimum possible dead space compatible with straight-through, unrestricted flow when open;
- a pressure sensor which is capable of detecting a minimum pressure change of approximately 0.05 mbar and which can be connected to a probe inserted in the mask cavity. The sensor shall have an adjustable threshold and be capable of differential signalling when the threshold is crossed in either direction. The sensor shall work reliably when subjected to the accelerations produced by the head movements of the subject;
- an interfacing system to actuate the valve in response to a signal from the pressure sensor; and
- a timing device to record the proportion of the total respiratory cycle during which sampling took place.

A-4.3.2.5 Sampling probe

The probe consists of a length of 1 mm bore hypodermic tube fitted securely in an airtight manner to the facepiece as near as possible to the centre line of the mask. A plastic ball of approximately 20 mm diameter with 8 holes each of 1.5 mm diameter and spaced equidistant around the circumference of the ball is fitted onto the hypodermic tube. The probe is adjusted so that the ball just touches the wearer's lips.


A-4.3.2.6 Sample pump

If no pump is incorporated into the photometer an adjustable flow pump is used to withdraw an air sample

IS 14746 : 1999

from the facepiece under test. This pump is so adjusted as to withdraw a constant flow of 1 l/min from the

sample probe. Dependent on the type of photometer it may be necessary to dilute the sample with clean air.



A-4.3.2.7 Sampling of hood/chamber concentration

The hood/chamber (see Fig. 6) aerosol concentration is monitored during the tests using a separate sampling system, to avoid contamination of the facepiece sampling lines. It is preferable to use a separate flame photometer for this purpose. If a second photometer is not available, sampling of the hood/chamber concentration using a separate sampling system and the same photometer may be made. However, time will then be required to allow the photometer to return to clean background.

A-4.3.2.8 Pressure detection probe

A second probe is fitted near to the sample probe and is connected to the pressure sensor.

A-4.3.3 Calculation

The leakage P shall be calculated from measurements made over the last 100 seconds of each of the exercise period to avoid carry over of results from one exercise to the other:

$$P \text{ (percent)} = \frac{C_2}{C_1} \times \frac{t_{\text{IN}} + t_{\text{EX}}}{t_{\text{IN}}} \times 100$$

where

- C_1 = challenge concentration
- C_2 = measured mean concentration
- t_{IN} = total duration of inhalation
- t_{EX} = total duration of exhalation

Measurement of C_2 is preferably made using an integrating recorder.

A-5 FLAMMABILITY

The brand new facepiece shall be tested for flammability with the test rig described in Annex E of IS 14166 for full face masks but shall be adjusted according to the following instructions:

For the test the facepiece shall be put on the metallic dummy head which shall be motorized such that it can describe a horizontal circle with variable control speed. The head shall pass over a Bunsen propane burner whose position can be adjusted. By means of suitable gauges, the height of the flame shall be set to 40 mm and the distance between the top of the burner and the lowest part of the facepiece passing through the flame shall be set to 20 mm. The head shall be set in motion and the effect of passing the facepiece once through the flame at (6 ± 0.5) cm/s shall be noted.




FIG. 6 APPARATUS USED IN THE DETERMINATION OF INWARD LEAKAGE USING SODIUM CHLORIDE

The temperature of the flame at a height of 20 mm above the burner tip shall be $800 \pm 50^\circ\text{C}$. The temperature shall be checked with a suitable measuring instrument.

When components such as valve(s) are arranged on other parts of the faceblank the test shall be repeated with other samples of the facepiece in the appropriate position.

A-6 CARBON DIOXIDE CONTENT OF THE INHALATION AIR

The apparatus consists essentially of breathing machine with solenoid valves controlled by the breathing machine, a connector, a CO_2 flowmeter and CO_2 analyzer.

The apparatus subjects the facepiece to a respiration cycle by the breathing machine. For this test the facepiece shall be fitted securely in a leak-tight manner but without deformation on a dummy head (type Sheffield) (see Fig. 7).

Air shall be supplied to it from a breathing machine adjusted to 25 strokes/min and 2.0 l/stroke and the exhaled air shall have a carbon dioxide content of 5 percent by volume.

A typical test arrangement is shown in Fig. 8.


To prevent a CO_2 build-up due to design of the test equipment a CO_2 absorber shall be used in the inhalation branch between solenoid valve and breathing machine. The CO_2 is fed into the breathing machine via a control valve, a flowmeter, a compensating bag and two non-return valves.

Immediately before the solenoid valve a small quantity of exhaled air is continuously withdrawn through a sampling line and then fed into the exhaled air via a CO_2 analyzer. To measure the CO_2 content of the inhaled air, 5 percent of the stroke volume of the inhalation phase of the breathing machine is drawn off at the marked place by an auxiliary lung and fed to a CO_2 analyzer. The total dead space of the gas path (excluding the breathing machine) of the test installation should not exceed 2 000 ml.

The carbon dioxide content of the inhaled air shall be measured and recorded continuously. This test shall be performed until a constant carbon dioxide content in this inhalation air is achieved.


A-7 FACEPIECE CONNECTOR

The test time shall be 10 seconds. The facepiece shall



All dimensions in millimetres.

FIG. 7 DUMMY HEAD (SHEFFIELD HEAD) FOR CARBON DIOXIDE CONTENT TEST OF THE INHALATION AIR (DEAD SPACE) FOR A FULL FACE MASK



- | | |
|----------------------|--|
| 1. Breathing machine | 6. Carbon dioxide analyzer |
| 2. Auxiliary lung | 7. Solenoid valves |
| 3. Non-return valve | 8. Dummy head |
| 4. Flow meter | 9. Sampling tube for inhalation air (see Fig. 9) |
| 5. Compensator | 10. Carbon dioxide absorber |

FIG. 8 SCHEME OF TEST RIG FOR CARBON DIOXIDE CONTENT OF THE INHALATION AIR

be supported on a dummy head, which can be adjusted so that the load can be applied axially to the connection (see Fig. 9). Additionally, a system of restraining straps or bands shall be fitted over the faceblank around the connection, so that the load is applied as directly as possible to the fitting of the connection in the faceblank

and the restraining force is not applied wholly to the head harness.

A-8 FIELD OF VISION

The field of vision shall be measured with an 'Apertometer' according to Stoll (see Fig. 10). A diagram (see Fig. 11) shall be used for the evaluation.

Procedure to measure the field of vision of a facepiece:

- Carefully fit the facepiece to the dummy head and, with both eyes lit, adjust the facepiece until the outline is symmetrical on the spherical shell. Adjust the tension of the straps to obtain a reasonable, secure fit.
- Map the positions of the field of vision of each eye individually on to the printed diagram, using the grid lines as a guide.
- Carefully measure the areas of the total field of vision and the overlapped field of vision with






FIG. 9 TEST ARRANGEMENT FOR TENSILE FORCE



All dimensions in millimetres.

FIG.10 APERTOMETER



... natural field of vision with
natural overlapped field of vision.

The areas enclosed by circular lines of the diagram are proportional to the corresponding areas marked on the spherical shell of the apertometer.

Semi-circular surface represented inside of the 90° circle.	= 126,9 cm ²
Natural field of vision inside of the 90° circle (78,8%)	= 100,0 cm ²
Natural field of vision outside of the 90° circle	= 12,0 cm ²
Natural field of vision totally	= 112,0 cm ² $\cong$ 100%
Natural field of vision totally.....	= 39,0 cm ² $\cong$ 100%

Shape of lenses : _____
(dimensions)

facepiece model: _____

Where measurements of the field of vision are taken, the effective field of vision as observed by the apertometer shall be transferred to the diagram. Only the effective field of vision within the natural field of vision respectively the effective overlapped field of vision shall be planimetered and noted in cm².

Planimetered area of effective field of vision (totally) cm².

Planimetered area of effective overlapped field of vision cm².

Effective field of vision (totally) %.

Effective overlapped field of vision %.

FIG.11 DIAGRAM OF THE APERTOMETER

a planimeter. The field of vision is the innermost line at any point of either the field of vision of the facepiece, or the natural field of vision of men according to Stoll as shown on the printed diagram.

Express the results as a percentage of the area of the natural field of vision of men according to Stoll (already marked on the diagram).

A-9 BREATHING RESISTANCE

The facepiece shall be fitted securely in a leak-tight manner but without deformation on a dummy head. The resistance shall be measured at the opening for the mouth of the dummy head using the adapter shown in Fig. 7 and a breathing machine adjusted to 25 strokes/min and 2.0 l/stroke or a continuous flow of 160 l/min. A resistance value shall be corrected to 27°C and 1 bar absolute.

ANNEX B

(Clause 4.7)

METHOD OF TEST FOR EXHALATION VALVE LEAKAGE

(This Annex is for information only)

B-1 APPARATUS

This consists mainly of :

- a) a small volume (volume : 1 to 1.21) leak tight box attached to a tube with opening (s) between the box and tube in which the valve assemblies are mounted in suitable adaptors of low dead space (*see* Fig. 12). There are baffle plates in the box to promote smooth test gas flow (100 l/min continuous flow);
- b) a breathing machine delivering sinusoidal air flows corresponding to 20 strokes/min and 1.5 l/stroke;
- c) a supply of CO₂;
- d) a purifier containing absorbent for CO₂;
- e) a unit to saturate the air with water vapour at 37°C; and
- f) an instrument capable of measuring test gas concentrations.

B-2 PROCEDURE


All the exhalation valve assemblies attached to the

facepiece are tested. The test is performed at ambient temperature and relative humidity. The valve assemblies under test are fitted into the box with a suitable, adaptor in a vertical position. The components are arranged according to whether a single or twin cylinder breathing machine is to be used (*see* Fig. 13 and 14).

The inlet valve is adjusted so that the back pressure of the valve(s) is 1 to 1.5 mbar at 30 l/min continuous flow. The breathing machine is set at 1.5 l/stroke, 20 strokes/min. A flow of test gas is maintained through the box. Samples of the air from before and after the valve assemblies are continuously analyzed for test gas concentrations.


The test is run for a sufficient time to obtain a steady reading of the test gas concentration in the inspiratory air stream.

The difference in the test gas concentrations between the two samples is a measure of the total valve leakage. The test shall be carried out using carbon dioxide.



- | | |
|---------------------|-------------------------------|
| 1. Test gas in | 5. Test gas out |
| 2. Baffle plates | 6. To breathing machine |
| 3. Blanking plate | 7. Pressure measurement ports |
| 4. Valve under test | 8. Saturated gas in |


FIG.12 SCHEME OF EXHALATION VALVE LEAKAGE TEST BOX



- | | |
|-----------------------------|---------------------------------|
| 1. Test gas in | 7. Purifier |
| 2. Valve under test | 8. Reference gas sample |
| 3. Test gas out | 9. Purifier |
| 4. Breathing machine valves | 10. Laboratory air in |
| 5. Breathing machine | 11. Adjustable non-return valve |
| 6. Saturator | 12. Test gas sample |

The difference between concentrations of samples taken at points 8 and 12 is a measure of the valve leakage.

FIG.13 SCHEME OF TEST RIG FOR VALVE LEAKAGE USING A SINGLE CYLINDER MACHINE



- | | |
|-------------------------|--|
| 1. Test gas in | 7. Laboratory air in through adjustable non-return valve |
| 2. Valve under test | 8. Saturator |
| 3. Test gas out | 9. Twin cylinder breathing machine |
| 4. Purifier | 10. Laboratory air in |
| 5. Reference gas sample | 11. Test gas sample |
| 6. Purifier | 12. Breathing machine valves |

The difference between concentrations of the samples taken at points 5 and 11 is a measure of the valve leakage.

FIG.14 SCHEME OF TEST RIG FOR VALVE LEAKAGE USING A TWIN CYLINDER BREATHING MACHINE

ANNEX C

(Foreword)

COMMITTEE COMPOSITION

Industrial Safety Sectional Committee, CHD 08

<i>Chairman</i>	<i>Representing</i>
SHRI K. C. GUPTA	National Safety Council, Mumbai
<i>Members</i>	
SHRI PREM BAWEJA SHRI B. VIJAY KUMAR (<i>Alternate</i>)	Hindustan Aeronautics Ltd, Bangalore
DR A. K. BORAL SHRI R. SRINIVASAN (<i>Alternate</i>)	Ministry of Defence (DGQA), New Delhi
DR D. R. CHAWLA SHRI M. K. BANERJEE (<i>Alternate</i>)	Department of Industrial Development, New Delhi
DIRECTOR (MINES SAFETY) SHRI A. K. RUDRA (<i>Alternate</i>)	Directorate General of Mines Safety, Dhanbad
SHRI V. K. GOEL SHRI M. L. AHUJA (<i>Alternate</i>)	Central Boiler Board, New Delhi
SHRI J. P. GOENKA SHRI N. DUTTA (<i>Alternate</i>)	Mining, Geological and Metallurgical Institute of India, Calcutta
SHRI M. KANT SHRI KIRIT MARU (<i>Alternate</i>)	Safety Appliances Manufacturers Association, Mumbai
SHRI SURENDRA KUMAR SHRI R. PARTHASARATHY (<i>Alternate</i>)	Indian Chemical Manufacturers Association, Calcutta
DR J. MAHAPATRA	Standing Committee on Safety for Steel Industry, SAIL, Ranchi
SHRI M. K. MALHOTRA	Directorate General Factory Advice Services and Labour Institutes, Mumbai
SHRI H. N. MIRASHI	Factory Inspectorate, Govt of Maharashtra, Mumbai
DR H. MUKHERJEE SHRI C. M. SHARMA (<i>Alternate</i>)	Chief Controller of Explosives, Nagpur
SHRI R. N. MUKHERJEE SHRI A. BANERJEE (<i>Alternate</i>)	Central Mining Research Institute, Dhanbad
SHRI S. K. MUKHERJEE SHRI A. K. GHOSH (<i>Alternate</i>)	Standing Fire Advisory Council, New Delhi
SHRI R. K. PODDAR	Larsen & Toubro Ltd (ECC Construction Group), Chennai
SHRI BHAGWATI PRASAD SHRI SATISH CHANDER (<i>Alternate</i>)	Employees State Insurance Corporation, Calcutta
SHRI P. S. PRUTHI SHRI SURESH KAPOOR (<i>Alternate</i>)	Indian Pesticides Association, New Delhi
SHRI P. RAJENDRAN SHRI H. S. RAWAT (<i>Alternate</i>)	Directorate General Civil Aviation, New Delhi
SHRI A. RAMAMURTHY	Bhabha Atomic Research Centre, Mumbai
SHRI K. RAVICHANDRAN SHRI M. SRIVASTAVA (<i>Alternate</i>)	Ministry of Petroleum and Natural Gas (Oil Industries Safety Directorate), New Delhi

(Continued on page 20)

IS 14746 : 1999

(Continued from Page 19)

Members

SHRI A. J. REGO
SHRI R. P. BHANUSHALI (*Alternate*)
REPRESENTATIVE

DR S. SADULLA
SHRI G. SWAMINATHAN (*Alternate*)

SHRI M. R. SAMPATH
SHRI O. N. DAGA (*Alternate*)

SHRI P. N. SANKARAN
SHRI V. K. SRIVASTAVA (*Alternate*)

SHRI G. P. YADAV
SHRI N. JAIPAL (*Alternate*)

DR R. K. SINGH,
Director (Chem)

Representing

National Safety Council, Mumbai

Confederation of Indian Industries, New Delhi

Central Leather Research Institute, Chennai

Indian Cotton Mills Federation, Mumbai

Indian Space Research Organization, Shriharikota

National Institute of Occupational Health, Ahmedabad

Director General BIS (*Ex-officio Member*)

Member-Secretary

SHRI P. MUKHOPADHYAY
Additional Director (Chem), BIS

Panel for Respiratory Protective Equipment, CHD 08:01/P1

Convener

SHRI R. N. MUKHERJEE

Central Mining Research Institute, Dhanbad

Members

SHRI VIVEK BHARGAVA
SHRI VIKAS BHARGAVA (*Alternate*)

SHRI S. CHATTOPADHYAY
SHRI K. K. DUTTA (*Alternate*)

SHRI S. K. DANGWAL
SHRI M. H. FULEKAR (*Alternate*)

DIRECTOR (MINES SAFETY)
SHRI A. K. RUDRA (*Alternate*)

SHRI A. N. INDURKAR
SHRI PRATAP NAIR (*Alternate*)

SHRI S. K. MUKHERJEE
SHRI B. R. MEHTA (*Alternate*)

SHRI C. PERREIRA
SHRI DON RISHBERT (*Alternate*)

SHRI S. SANYAL

SHRI J. N. SHARMA

Industrial Medical Engineers, New Delhi

Ministry of Defence (DGQA), New Delhi

Central Labour Institute, Mumbai

Directorate General of Mines Safety, Dhanbad

Mines Safety Appliances, Calcutta

Institute of Fire Engineers, New Delhi

Joseph Leslie Drager Mfg & Co, Mumbai

Coal India Ltd, Calcutta

Indian Petrochemicals Ltd, Vadodara